ERG Distribution_SHADE_LIGHT

JOHN HARGREAVES AVENUE

FARR ROAD

SUTTOR AVENUE

CHELMSFORD AVENUE

END OF DUCT UNKNOWN

EOP 9.8

ST1 A3

EOP 7.5

P1 0.0

EOP 3.5

ST1 0.8

EOP 1.2

END OF DUCT UNKNOWN

EXISTING POLE

4 x 125 PVC

4 x 125 PVC

Corner of building

Boundary or building

14

14a

15

16

17

19

229

129

128

176

177

29

28

30

31

215

216

JOINT DETAIL REPORT

No.	Str Pp	RSOn	Joint Location
Map: SY44243			
28		0.60/0.60	0.6m NW of SX436
29		0.60/0.60	0.6m NW of SX436
30	646-88	1.52/0.61	7.0 S OF HOWARD ST EXT NBL
31	646-88	1.52/0.61	7.0 S OF HOWARD ST EXT NBL
32	EP88-079	2.90/99.00	36.0m N from Brick Wall of Horden Pavilion
33	EP88-079	2.90/99.00	36.2m N from Brick Wall of Horden Pavilion
115	646-88	1.52/0.61	7.0 S OF HOWARD ST EXT NBL
116	646-88	1.52/0.61	7.0 S OF HOWARD ST EXT NBL
128			
129			
176	IO35-341	13.40/1.20	4.3 N OF BLDG NO.19
177	IO35-341	13.40/1.20	1.5 S OF BDLG NO.19

WARNING

Ausgrid's plans show the position of assets at the time of installation and may not account for subsequent changes to road alignments, fences or buildings. The plans show no more than the presence or absence of Ausgrid assets in the street.
Persons working near electricity networks must exercise care and will be held responsible for any damage caused.
You must excavate by hand or use vacuum excavation to establish the location of Ausgrid underground cables and associated assets.
Underground: Working near a cable may result in electric shock even if no contact is made. Any work in the vicinity of any cable should only be performed using safe work methods developed in accordance with the recommendations contained in the relevant NSW Code of Practice for Excavation and SafeWork NSW Guide for Work Near Overhead Powerlines
as well as recommendations of Ausgrid's Network Standard NS156.
Overhead: Do not excavate near poles or towers until the stability of the foundation has been assessed by Ausgrid. Cables or earth conductors may be present close to substations, poles or towers.
Workers must maintain safe approach distances and follow applicable SafeWork NSW Codes of Practice.
NOTE: 1. You must keep Ausgrid plans on site during excavation works. If the people actually performing the excavation works do not know how to read and interpret Ausgrid's plans, then the work must be directed by a person who knows how to read and interpret the plans. 2. This information includes data from the NSW Digital Cadastral Database by Land and Property Information (c) 2016, used under Creative Commons licence version 4.0

N

SY44232	SY44241	SY44242
SY44234	SY44243	SY44244
SY44412	SY44421	SY44422

SSD GRID

SY44243

MOCS

INFORMATION ON THIS PLAN ONLY VALID FOR 30 DAYS FROM ISSUE DATE

Page 1 of 1

1:250

0 15 metres

Ausgrid