JOINT DETAIL REPORT

No....	Bk.Pg	PI/Cor	Joint Location .....
Map: SY444			
13	ER92-117		Outside SS154
14	ER87-042		Outside SS154
15	ER87-042		Outside SS154
16	ER87-042		Outside SS154
206	ES27-0271	5.30/0.90	
207	ES27-0271	5.30/0.80	

WARNING

Ausgrid's plans show the position of assets at the time of installation and may not account for subsequent changes to road alignments, fences or buildings. The plans show no more than the presence or absence of Ausgrid assets in the street.

Persons working near electricity networks must exercise care and will be held responsible for any damage caused.

You must excavate by hand or use vacuum excavation to establish the location of Ausgrid underground cables and associated assets.

Underground: Working near a cable may result in electric shock even if no contact is made. Any work in the vicinity of any cable should only be performed using safe work methods developed in accordance with the recommendations included in SafeWork NSW Code of Practice for Excavation and SafeWork NSW Guide for Work Near Underground Assets

as well as recommendations of Ausgrid's Network Standard NS156.

Overhead: Do not excavate near poles or towers until the stability of the foundation has been assessed by Ausgrid. Cables or earth conductors may be present close to substations, poles or towers.

Workers must maintain safe approach distances and follow applicable SafeWork NSW Codes of Practice.

NOTE: 1. You must keep Ausgrid plans on site during excavation works. If the work is performed by persons performing the excavation works do not know how to read and interpret Ausgrid's plans, then the work must be directed by a person who knows how to read and interpret the plans. 2. This information includes data from the NSW Digital Cadastral Database by Land and Property Information (c) 2016, used under Creative Commons licence version 4.0.

N

SY44243	SY44244	SY53133
SY44421	SY44422	SY53311
SY44423	SY44424	SY53313

ISCG GRID

SY44422

MOCS

INFORMATION ON THIS PLAN ONLY VALID FOR 30 DAYS FROM ISSUE DATE

Page 1 of 1

1:250

0 — 15 metres

Ausgrid

A0 MOCS_std_plot

SEPO_Distribution_SY44422_1.mapd