


SY444 - CN1

Ref: D8



No.	Ref.	Point	Asset Location
101	ES05-074	5.881.20	10.7m NE of LANG RD NEPL
102	ES05-074	5.881.20	10.7m NE of LANG RD NEPL

WARNING
Ausgrid is not responsible for the position of assets at the time of installation and may not account for subsequent changes to road alignments, fences or buildings. The plans show no more than the presence or absence of Ausgrid assets in the street.
Persons working near electricity networks must exercise care and will be held responsible for any damage caused.
You must excavate by hand to use vacuum excavation to establish the location of Ausgrid underground cables and associated assets.
Underground: Working near a cable may result in electric shock even if no contact is made. Any work in the vicinity of any cable should only be performed using safe work methods developed in accordance with the recommendations included in SafeWork NSW Code of Practice for Excavation and SafeWork NSW Guide for Work Near Underground Assets as well as recommendations of Ausgrid's Network Standard NS156.
Overhead: Do not excavate near poles or towers until the stability of the foundation has been assessed by Ausgrid. Cables or earth conductors may be closer close to substations, poles or towers.
Workers must maintain safe approach distances and follow applicable SafeWork NSW Code of Practice.
NOTE: 1. You must keep Ausgrid plans on site during excavation works. If the people actually performing the excavation works do not know how to read and interpret Ausgrid's plans, then the work must be directed to a person who knows how to read and interpret the plans. 2. This information includes data from the NSW Digital Customer Database by Land and Property Information (c) 2016, used under Creative Commons license version 4.0.

N

SY44424

MOCS

Page 1 of 1

1:250

15 metres

Ausgrid

SY44421

SY44422

SY44423

SY44424

SY44425

SY44421

SY44422

SY44423

SY44424

SY44425

MOCS

SY44421

SY44422

SY44423

SY44424

SY44425